



GRANVILLE COUNTY ENVIRONMENTAL PROGRAMS

141 WILLIAMSBORO STREET, POST OFFICE BOX 906, OXFORD, NORTH CAROLINA 27565- 0906


Office (919) 603-1354

Fax (919) 690-8610

Email: recycle@granvillecounty.org

MEMORANDUM

To: Mary

From: Jason Falls 

Date: June 8, 2007

Re: Closure of Water Supply Well at Butner

Attached is a copy of the notification of the water well closure at Butner. If you have any questions, please call.



JF/jf

WELL ABANDONMENT RECORD WELL CONTRACTOR Stephenson's Well Drilling, Inc.
WELL CONTRACTOR CERTIFICATION # 2421

1. WELL USE (Check Applicable Box): Residential ☐ Municipal ☐ Industrial ☐ Agricultural ☐ Monitoring ☐
Recovery ☐ Heat Pump Water Injection ☒ Other ☐ If Other, List Use: LANDFILL

2. WELL LOCATION: (Show a sketch of the location on back of form.)
Nearest Town: Butner, N.C. County GLANVILLE
SR. # 1004 Old Hwy. 75
(Road Name and Number, Community, Subdivision, Lot No.) Quadrangle No.

3. OWNER: GLANVILLE County

4. ADDRESS: P.O. Box 906, Oxford, N.C. 27565

5. TOPOGRAPHY: draw, slope, hilltop, valley, flat
(circle one)

6. TOTAL DEPTH: 205' DIAMETER 6"

7. CASING REMOVED:
feet 3' diameter 6"

8. DISINFECTION: 12 oz.
(Amount of 70% hypochlorite used;)

9. SEALING MATERIAL:

Neat Cement
47 lb. - bags of cement 80
gallons of water 240

Sand Cement
bags of cement
gallons of water

Other
Type material
Amount

10. EXPLAIN METHOD EMPLACEMENT OF MATERIAL.

PRESSURE GROUTED WITH NEAT CEMENT FROM BOTTOM TO TOP

11. DATE WELL ABANDONED 5-29-07


I do hereby certify that this well was abandoned in accordance with 15A NCAC 2C, well construction standards, and that a copy of the record has been provided to the well owner.

Signature of person abandoning the well James D. Stephenson Jr. Date 5-29-07

WELL LOCATION: Draw a location sketch on the reverse of this sheet, showing the direction and distance of the well to at least two (2) nearby reference points such as roads, intersections and streams. Identify roads with State Highway road identification numbers.

Submit original to the Division of Water Quality, Groundwater Section, one copy to the owner within 30 days from completion of abandonment.

WELL DIAGRAM: Draw a detailed sketch of the well showing total depth, depth and diameter of screens remaining in the well, gravel intervals, intervals of casing perforations, and depths and types of fill materials used.



Butler Lake
ENTRANCE

Old Hwy 75 S.R.# 1004

1 mile

* Abandoned well

Butler
Landfill

ENTRANCE

33rd Street S.R.# 1112

To Butler Ave.